

## ROWLAND UNIFIED SCHOOL DISTRICT 1830 S. NOGALES STREET ROWLAND HEIGHTS, CA 91748

## ADDENDUM 1

LAN FIBER INSTALLATION E-RATE RFP BID# 2021-22 (R5)

JANUARY 14, 2022

## TO ALL PROSPECTIVE BIDDERS:

Note:

The following Addendum shall become part of the contract documents and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.

## **Specifications/Clarifications:**

- 1. Per page 23 Equipment Group 1 You are to utilize the existing conduit/pathways.
- 2. Per page 21 The cable lengths are for informational purposes only. The actual lengths are to be verified in the field by the contractor during the job walk.
- 3. Per page 24 All trenching through the asphalt and the concrete shall be saw cut.
- **4.** Per page 24 All trenching shall be back filled to 90% compaction.
- **5.** Per page 24 g. You are to Dowel in adjacent surfaces.
- **6.** Contractor to provide toilet and handwashing facilities for his/her employees throughout the duration of the project.

Rosana Mc Leod

Director of Purchasing