



ROWLAND UNIFIED SCHOOL DISTRICT  
1830 S. NOGALES STREET  
ROWLAND HEIGHTS, CA 91748

## **ADDENDUM 3**

DESIGN/BUILD NEW BUS & TRUCK SERVICE LIFTS  
PROJECT  
RFP BID# 2020/21:(R2)

NOVEMBER 17, 2020

TO ALL PROSPECTIVE BIDDERS:

Note: *The following Addendum shall become part of the contract documents and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.*

### **Specifications/Clarifications to Addendum 2**

- 1. Questions:** Can we clarify if it is the bidding contractor's responsibility to furnish all labor/materials/equipment for the electrical portion. The bid specs scope of work state that the District will provide all electrical up to the new equipment controls, but the plans/drawings on E-1.0 have a lot of language that refer to the contractor. Is it the contractor's responsibility or the District's?

**Answer:** The contractor will be responsible for all work shown on the electrical drawings.

1. All conduit shown from the disconnect switch to the lift hydraulic motor shall be run below grade.
2. All conduit shown from the lift hydraulic motor to the lift pit area shall be run below grade

*Rosana McLeod*

Director of Purchasing