



ROWLAND UNIFIED SCHOOL DISTRICT
1830 S. NOGALES STREET
ROWLAND HEIGHTS, CA 91748

ADDENDUM 3

ROWLAND HIGH SCHOOL – FENCE REPLACEMENT
RFP BID# 2019/20:(R3 - INFORMAL)

NOVEMBER 7, 2019

TO ALL PROSPECTIVE BIDDERS:

Note: *The following Addendum shall become part of the contract documents and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.*

Specifications/Clarifications:

1. Contractor is to install top, middle and bottom fence rails, as depicted in the attached photo.
2. Bid due date has been changed from November 14, 2019 at 10:00 a.m. to new due date of **November 21, 2019 at 2:00 p.m.**
3. Question: The Jasco Prep Primer Spec that you sent with addendum 2 is a discontinued product, according to the Jasco website. Please spec a different product.

Answer: Please replace the Jasco Prep Primer with Krud Kutter Pre-paint Cleaner TSP Substitute (see attached)

4. Question: I have been informed by a Rep. from Dunn Edwards that the Ultra Shield Primer will be discontinued soon as well, please advise?

Answer: Dunn Edwards in the City of Industry has advised the RUSD that the Ultra Shield Primer has not been discontinued and is the only galvanized primer they carry in stock. The phone number at the Dunn Edwards in the City of Industry is (626) 269-2868.

Rosana McLeod

Director of Purchasing