



ROWLAND UNIFIED SCHOOL DISTRICT  
1830 S. NOGALES STREET  
ROWLAND HEIGHTS, CA 91748

## **ADDENDUM 3**

LAN FIBER INSTALLATION E-RATE  
RFP BID# 2021-22 (R5)

FEBRUARY 4, 2022

TO ALL PROSPECTIVE BIDDERS:

*Note: The following Addendum shall become part of the contract documents, and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.*

### **Specifications/Clarifications:**

The project due date will be extended from **February 17, 2022, to March 3, 2022, no later than 10:00 A.M. NO Proposals will be accepted after 10:00 A.M. (PST)**

- Please confirm that Killian Elem. School requires a wall mount fiber optic enclosure at the MDF closet?
  - As outlined in the original RFP, a wall-mount fiber patch panel is acceptable in locations where rackmount is unavailable with approval from District on a case-by-case basis. During the mandatory job walks it was agreed that Killian Elementary would be a location requiring a wall-mounted fiber patch panel. It was also agreed that the District will provide sufficient backboard space to mount the new fiber patch panel.
- The drawing provided for Shelyn Elem. School does not include the underground conduit pathway to Portable Classrooms D1 – D8. Can you please provide the correct drawings that details these pathways?
  - The prints originally provided with the RFP outlined the pull boxes/vaults feeding these locations. For clarity, we have outlined them in red and included hash lines to help identify path direction. Please see the revised as-builds attached for Shelyn Elementary School.
- In the RFP I. Overview Section A. page 1-2, states “Proposals may be made using an existing piggybackable bid and/or an existing State of California contract, i.e. CMAS, or Western States Contracting Alliance, now known as NASPO ValuePoint.” If the bidder has a CMAS and/or a NASPO Contract that covers the proposed products and services, are they required to provide the actual Contract with our bid proposal?

- **Addendum 3 - Page 2 of 2**

- No, the bidder is only required to provide the first page of the contract which includes the contract number, bidder name, contract start date, and contract expiration date.
- If the CMAS and/or NASPO Contract is required with the bid proposal, we feel that the 60-page Proposal limitation will not be enough as these contracts are very large. Please confirm/clarify instructions for this section.
  - No, the bidder is only required to provide the first page of the contract which includes the contract number, bidder name, contract start date, and contract expiration date.
  - The CMAS and/or NASPO Contract will be required from the bidder before the Notice of Intent is issued.