



ROWLAND UNIFIED SCHOOL DISTRICT
1830 S. NOGALES STREET
ROWLAND HEIGHTS, CA 91748

ADDENDUM 1
BID No. 2019/20:(R20-I)
ALVARADO INTERMEDIATE EXTERIOR PAINTING

MAY 20, 2020

TO ALL PROSPECTIVE BIDDERS:

Note: *The following Addendum shall become part of the contract documents and the bidder shall provide for all work as required by this Addendum. Acknowledge receipt of the Addendum on the Bid Proposal Form.*

Specifications/Clarifications:

1) Paint wrought Iron fencing on the East side of the school campus (see site map for wrought iron fence location) between Administration Office and MPR/ Cafeteria. Use proper galvanize prepping procedures. See attached materials for galvanized prep and prime products. Paint color to be Blue Suede Shoes on the color chart.

2) Mask off all aluminum trim around windows and all expansion joints in stucco walls, they are NOT to be painted.

**3) Re-word the last sentence in the paragraph titled See Attached Specs.
Wording should read “prime all painted surfaces and apply two finish coats”.
Currently reads “prime all non -surfaces and apply two finish coats”.**

Rosana McLeod

Director of Purchasing